



# VAr-Min SR1

## Part Number

		Must Be Defined										Options			
		V	4	-											
<u>Down Cable Connection</u>															
	7-Pin Amphenol Connector	07													
**	14-Pin Amphenol Connector	14													
	6 Jaw Meter Base - A Config	6A													
	4 Jaw Meter Base - C Config	4C													
	6 Jaw Meter Base - D Config	6D													
	6 Jaw Meter Base - E Config	6E													
	6 Jaw Meter Base - F Config	6F													
	Internal Connecting Terminal Block	NT													
<u>Supply Voltage</u>															
	Single Phase 120 VAC	1													
	Three Phase 120 VAC	3													
<u>SCADA Communications</u>															
	None	0													
	Fiber with ST Connectors	F													
	Serial with DB-9 Connector	S													
(Phoenix Conn)	Serial Direct Hardwired	D													
(Define if using PoE)	Ethernet	E													
<u>Temperature Sensor</u>															
	None	0													
	Temp	T													
<u>Trip Operation Type</u>															
	AC Trip	A													
	DC Trip	D													
	AC and DC Trip	B													
<u>Current &amp; Voltage Sensing</u>															
	None	0													
(0-10V)	LPCS	L													
	CT	C													
**	(0-10V) LPCS	B													
	(0-148V) PT	PT													
<u>Cap Bank Wye Neutral Sensing</u>															
	None	0													
	CT	C													
(120V NOM Secondary)	PT	P													
<u>Enclosure</u>															
	10x12 Carlon w/ Meter Base	0													
(NMK10V)	10x12 Carlon w/ Carlon Brackets	1													
(VBK03)	10x12 Carlon w/ Aluminum Brackets	2													
<u>Compatible with:</u>															
		<u>DC Trip</u>													
Cooper ECS															
Joslyn VSV	Type 1	1													
ABB PSx5															
Cooper VCS-1S															
Maysteel UltraVac	Type 2	2													
<u>Backup Power</u>															
	Last Gasp	0													
	Extended Last Gasp	1													
<u>Options - Not Required</u>															
		(Dash)													
		-													
<u>Radio Part Number</u>															
	Freewave FGR2-PE-U	R1													
	Freewave FGR09CSU	R2													
	GE MDS SDx	R3													
	(User Specified Radio)	R0													
<u>Isolation Power Supply</u>															
	12 VDC	E1													
(Radio or PoE)	24 VDC	E2													
	48 VDC	E4													
	IEEE 802.3af	E0													

\*\* Three Phase VAr-Min ONLY